


# CITY OF FORT LUPTON CITY COUNCIL

Tommy Holton, Mayor



Chris Cross, Ward 3  
Zo Hubbard, Ward 2  
Shannon Crespin, Ward 1

Bob McWilliams, Ward 3  
S. David Norcross, Ward 2  
Debra Yates, Ward 1

Performance, Integrity, Teamwork,  
Accountability and Service

## UAM 2010-015

### AUTHORIZING PURCHASING RY-1000 FROM CHEMQUEST, INC. FOR THE CITY OF FORT LUPTON WATER SYSTEM FOR AN AMOUNT NOT TO EXCEED \$70,000

I. **Agenda Date:** Council Workshop – July 19, 2010  
Council Meeting – July 26, 2010

II. **Attachments:** A. Vendor Quote

III. **Summary Statement:**

As part of the treatment process for Corrosion Control in the City of Fort Lupton Water System, addition of a proprietary chemical is being used as the means of obtaining this corrosion control treatment. This purchase is necessary to continue the chemical addition

IV. **Fiscal Note:** See Section XI.

Finance Department Use Only

  
Finance Director

V. **Submitted by:**

  
Finance Director

VI. **Approved for Presentation:**

  
City Administrator

VII. **Certification of Council Approval:**

City Clerk

Date

**VIII. Detail of Issue/Request:**

*In order to supply the necessary additive to the City of Fort Lupton water system, it is necessary to purchase the product, RY-1000 from Chemquest, Inc., the supplier for this proprietary chemical. This is a Zinc Polyphosphate blend that has been identified as the city selected option to obtain the necessary corrosion control within the city water distribution system.*

*The last tanker load was ordered in February 2009; therefore it would last sixteen to seventeen months. We would not need to re-purchase this product until the latter part of 2011.*

*Information that some may not be familiar with: The corrosion control requirement is a part of the Lead & Copper Rule. This rule concerns lead & copper levels in customer homes and the water system's requirement to provide no corrosive water to our customers, in an effort to minimize lead or copper leaching out of plumbing lines that exist in each residence.*

**IX. Legal/Political Considerations:**

*N/A*

**X. Alternatives/Options:**

*N/A*

**XI. Financial Considerations:**

*This expense is budgeted in the water treatment department under repairs and maintenance.*

**XII. Staff Recommendation:**

*Approve UAM 2010-015 to purchase one tanker truck, approximately 4250 gallons, RY-1000 from Chemquest, Inc., for an amount not to exceed \$70,000.*

## Claud Hanes

---


**From:** Thom.Vinson@ch2m.com  
**Sent:** Thursday, June 10, 2010 10:35 AM  
**To:** Claud Hanes  
**Subject:** FW: RY 1000 Zinc Phosphate  
**Attachments:** UAM\_2009-004\_Chemquest\_for\_RY\_1000.doc

*Claud,*

*It is time again to order the corrosion control chemical for the Water Treatment Facility. Below is the bid price for the Zinc Phosphate and attached is the UAM from last year. Please let me know if you need anything further from me.*

*Thanks,  
Thom*

Thom Vinson,  
Office (303) 857-9442  
Cell (303) 506-2654

 Please consider the environment before printing this email.

---

**From:** Michael [mailto:mmcevoy@chemquest.us]  
**Sent:** Wednesday, June 09, 2010 3:33 PM  
**To:** Vinson, Thom/FLU  
**Subject:** RY 1000 Zinc Phosphate

Dear Thom,

I am pleased at this time to provide the following price for you consideration:

4250 gallon RY 1000 \$16.45/gallon \$69,912.50

Price includes bulk delivery to: Ft. Lupton Water Treatment Plant.

Thanks!

***Mike McEvoy***

Mike McEvoy  
Chemquest, Inc.  
President  
785-232-2722  
[mmcevoy@chemquest.us](mailto:mmcevoy@chemquest.us)

**This message and any attachment are privileged and confidential. If you are not the intended recipient, please telephone or email the sender and delete the message and any attachment from your system. If you are the intended recipient you may not copy this message or attachment or disclose the contents to any other person**

1/3